

	CONC.		BAR SIZE													
		#3	#4	#5	#6	#7	#8	#9	#10							
F	P.S.I.	TEN	I SI	ON	LA	ıΡ	SPL	ICE	S,	INC	HES					
	4,000	25	33	41	49	69	81	91	103							

HARDROCK CONCRETE F'y = 60,000 P.S.I. (CLASS "B")


- I. SPLICE LENGTH SHALL BE DETERMINED FROM THE SIZE OF THE SMALLER BAR SPLICED.
- 2. DIVIDE BY 1.3 FOR NON-TOP BAR (LESS THAN 12" OF CONCRETE CAST BELOW)

HORIZONTAL REINFORCING LAP SPLICE VAR






BAR SPLICE



135 DEG BEND

REINFORCING BAR BEND SIZE DIAMETER ("D
#3 TO #8 6d
#9 TO #II 8d
#14 TO #18 10d




90 DEG BEND

BAR CLEARANCE

NOTE: ALL BENDS SHALL BE MADE COLD

TYPICAL BAR BENDS NTS VAR




- I. CONTRACTOR'S OPTION TO POUR PADS SEPARATELY FROM FLOOR SLAB AT PADS ON STRUCTURAL FLOOR.
- 2. EQUIPMENT ANCHORAGE EMBEDS ARE UNIQUE TO EACH PIECE OF EQUIPMENT, SEE DETAIL A, SHEET S-06.

EQUIP PAD DETAIL В VAR





NOT MEASURE IS THEN DRAWING I NOT TO SCALE.



METROPOLITAN WASTEWATER DEPARTMENT

City of San Diego

SUMMARY OF SPECIAL INSPECTION

- 1 CONCRETE
 2 BOLTS INSTALLED IN CONCRETE
 3 CONCRETE MOMENT RESISTING SPACE FRAME
 4 REINFORCING STEEL AND PRESTRESSING STEEL
 1 ALL STRUCTURAL WELDING
 2 WELD LASTING DUCTILE MOMENT-RESISTING STEEL FRAME
 3 WELDING REINFORCING STEEL
 6 HIGH-STRENGTH BOLTING
 7 STRUCTURAL MASONRY
 8 REINFORCED GYPSUM CONCRETE
 9 INSULATING CONCRETE FILL
 10 SPRAY-APPLIED FIREPROOFING
 11 DEEP FOUNDATIONS (PILLING, DRILLED PIERS & CAISSC
 12 SHOTCRETE DEEP FOUNDATIONS (PILLING, DRILLED PIERS & CAISSONS) SHOTCRETE

- 13.1 VERIFY SOIL CONDITIONS ARE SUBSTANTIALLY IN CONFORMANCE WITH
 THE SOIL INVESTIGATION REPORT
 13.2 VERIFY THAT FOUNDATION EXCAVATIONS EXTEND TO PROPER DEPTH
 AND BEARING STRATA
 13.3 PROVIDE SOIL COMPACTION TEST RESULTS, DEPTH OF FILL, RELATIVE
 DENSITY, BEARING VALUES
 13.4 PROVIDE SOIL EXPANSION TEST RESULTS, EXPANSION INDEX,
 RECOMMENDATIONS FOR FOUNDATION, ON GRADE FLOOR SLAB
 DESIGN FOR EACH BUILDING SITE
 14 SMOKE CONTROL SYSTEM
 15 SPECIAL CASE (DESCRIBE)
 16 OFF-SITE FABRICATION OF BUILDING COMPONENTS
 17 OTHER STRUCTURAL INSPECTIONS AS REQUIRED BY DESIGNER

No.	DESCRIPTION OF TYPE OF INSPECTION REQUIRED, LOCATION, REMARKS, ETC.	Design Strength
1	CONCRETE (ALL CONCRETE, U.N.O.)	F'c = 4,000 P.S.I.
2	ALL BOLTS INSTALLED IN CONCRETE	ICBO #5193
4	PLACEMENT OF REINFORCING STEEL AT CONCRETE	
13.1 13.2 13.3 13.4	SOILS REPORT	3.000 PSF

THE SPECIAL INSTRUCTIONS LISTED ARE IN ADDITION TO THE CALLED INSPECTIONS REQUIRED BY SECTION 108 OF THE CBC, AS AMENDED. SPECIAL INSPECTION IS NOT A SUBSTITUTE FOR INSPECTION BY A CITY INSPECTOR.

CONTINUOUS INSPECTION IS ALWAYS REQUIRED DURING THE PERFORMANCE OF THE WORK UNLESS OTHERWISE SPECIFIED. WHEN WORK IN MORE THAN ONE CATEGORY OF WORK REQUIRING SPECIAL INSPECTION IS TO BE PERFORMED SIMULTANEOUSLY, OR THE GEOGRAPHIC LOCATION OF THE WORK IS SUCH THAT IT CAN NOT BE CONTINUOUSLY OBSERVED IN ACCORDANCE WITH THE PROVISIONS OF CBC SECTION 1701.8.1 IT IS THE AGENT'S RESPONSIBILITY TO EMPLOY A SUFFICIENT NUMBER OF INSPECTORS TO ASSURE THAT ALL THE WORK IS INSPECTED IN ACCORDANCE WITH THOSE PROVISIONS.

THE SPECIAL INSPECTIONS MUST BE CERTIFIED BY THE CITY OF SAN DIEGO TO PERFORM THE TYPE OF INSPECTION SPECIFIED.

- EXCEPTIONS:
 1. SOILS INSPECTIONS BY THE SOILS ENGINEER OF RECORD.
 2. SMOKE CONTROL SYSTEM, BY THE MECHANICAL ENGINEER OF RECORD.
 3. WHEN WAIVED BY THE BUILDING OFFICIAL.

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO NOTIFY THE SPECIAL INSPECTOR OR INSPECTION AGENCY AT LEAST ONE WORKING DAY PRIOR TO PERFORMING ANY WORK THE REQUIRES SPECIAL INSPECTION.

SPECIALLY INSPECTED WORK THAT IS INSTALLED OR COVERED WITHOUT THE APPROVAL OF THE CITY INSPECTOR IS SUBJECT TO REMOVAL OR EXPOSURE.


A CERTIFICATE OF SATISFACTORY COMPLETION OF WORK REQUIRING SPECIAL INSPECTION MUST BE COMPLETED AND SUBMITTED TO THE INSPECTION SERVICES DIVISION.

THE SPECIAL INSPECTIONS IDENTIFIED ARE IN ADDITION TO THOSE REQUIRED BY SEC.108 OF THE BUILDING CODE, AS AMENDED. SPECIAL INSPECTION IS NOT A SUBSTITUTE FOR INSPECTION BY A CITY INSPECTOR.

A CERTIFICATE OF COMPLIANCE FOR OFF-SITE FABRICATION MUST BE COMPLETED AND SUBMITTED TO THE INSPECTION SERVICES DIVISION PRIOR TO ERECTION OF PREFABRICATED COMPONENTS.

					DRAWING NO. S-02								MENT PLANT OT STUDY
					S	неет 4	NO.		TYF	PICAL	DE	TAILS	S
													WATER NA
								CITY OF SA SHEET		EGO, CA E 22 SHE		RNIA	WATER NA SEWER NA W.O. NA
	DRAWING ST	ATUS						PROJECT MANAGER			DATE		
ATE REQ. REVI	ION DESCRIPTION	DRAWN	CKD	APD	PE	ЕМ	QA/QC	DESCRIPTION	BY	APPROVED	DATE	FILMED	
													DESIGN ENGINEER


										SHEET		22 SHE			SEWER NA
			DRAWING STA	TUS						PROJECT MANAGER			DATE		
١٥.	DATE	REQ.	REVISION DESCRIPTION	DRAWN	CKD	APD	PE	ЕМ	QA/QC	DESCRIPTION	BY	APPROVED	DATE	FILMED	
															DESIGN ENGINEER
															CONTROL CERTIFICATION
				_											188-1692
				-											LAMBERT COORDINATES
	+			+						CONTRACTOR		ATE STARTE			00000- 14 -D



00000- 16 -D

VERTICAL

NONE



MECHANICAL/ELECTRICAL/MEDICAL ANCHORAGE SCHEDULE


В


С

В

- ANY SUBSTITUTIONS MUST BE APPROVED BY THE ENGINEER OF RECORD.
- 2. HILTI HIT HY-150, ICBO #5193 WHERE INDICATED.
- 3. WHEN INSTALLING DRILLED-IN ANCHORS IN EXISTING REINFORCED CONCRETE, USE CARE AND CAUTION TO AVOID CUTTING OR DAMAGING THE EXISTING REINFORCING
- IF EQUIPMENT DOES NOT HAVE SUFFICIENT NUMBER OF SYMMETRICALLY LOCATED ANCHORAGE POINTS DRILL AND TAP THE REQUIRED NUMBER OF EQUALLY SPACED HOLES TO LOCATE ANCHOR BOLTS.
- 5. AT LEAST ONE ANCHOR BOLT SHALL BE LOCATED AT THE CORNERS OF THE EQUIPMENT WHERE OCCUR.








SNUBBER ANCHORAGE DETAIL

SNUBBER ANCHORAGE DETAIL

<u>C</u>



В

OPENING PER CIVIL TYP L4x3X^I/₄ TYP CLR (4) ½" DIA × 4½" EMB HILTI HIT HY-150 EPOXY ANCHOR (ICBO # 5193) (E) 12" CONC. WALL

STAIR SECTION

CORE HOLE REINF

E M-5

POINT LOMA WASTE WATER TREATMENT PLANT

BIOLOGICAL AERATED FILTER PILOT STUDY

STRUCTURAL DETAILS

SIMON WONG NO. 2906 EXP. 6-30-04 STRUCTURAL OF CALEGORIA

WARNING F THIS BAR DOES

NOT MEASURE I'
THEN DRAWING IS
NOT TO SCALE.

BROWN AND CALDWELL HORIZONTAL NO SCALE SCALE VERTICAL NO SCALE

METROPOLITAN WASTEWATER DEPARTMENT

City of San Diego



							ı				CITY OF SA SHEET		GO, CA 22 SHE		RNIA	W.O. NA SEWER NA
				DRAWING STA	TUS						PROJECT MANAGER			DATE		
	NO.	DATE	REQ.	REVISION DESCRIPTION	DRAWN	CKD	APD	PE	EM	QA/QC	DESCRIPTION	BY	APPROVED	DATE	FILMED	
																DESIGN ENGINEER
١																
'																CONTROL CERTIFICATION
					\vdash											188-1692
																LAMBERT COORDINATES
											CONTRACTOR		ATE STARTE ATE COMPLE			00000 18D

DRAWING NO

S-06

SHEET NO.

18


CONDUIT PLAN	SINGLE LINE DIAGRAM	SCHEMATIC DIAGRAM	DESCRIPTION.							
	°) 30A 3P	.)	CIRCUIT BREAKER. TRIP RATING AND NUMBER OF POLES INDICATED.							
		0 0	THREE POSITION SWITCH MAINTAINED CONTACT FUNCTION MAY VARY AS NOTED ON DIAGRAMS. CENTER POSITION IS OFF							
		0 0	TWO POSITION SWITCH. MAINTAINED CONTACT FUNCTION MAY VARY AS NOTED ON DIAGRAMS							
		مله	MOMENTARY CONTACT PUSHBUTTON, FUNCTION MAY VARY AS NOTED ON DIAGRAMS							
Los		LOS	MOMENTARY CONTACT PUSHBUTTON WITH PROVISION FOR LOCKOUT.							
	• •	°	LOCKABLE DISCONNECT SWITCH RATING AND DETAILS AS NOTED ON DRAWINGS.							
ZS		J°	LIMIT SWITCH. NORMALLY OPEN							
ZS		٠ <u>٠</u>	LIMIT SWITCH. NORMALLY CLOSED							
		→°NOTO	TIME DELAY RELAY CONTACT. OFF DELAY, NORMALLY OPEN, TIME OPEN							
		~ √ NCTC	TIME DELAY RELAY CONTACT. OFF DELAY, NORMALLY CLOSED, TIME CLOSED							
		°₹°Notc	TIME DELAY RELAY CONTACT. ON DELAY, NORMALLY OPEN, TIME CLOSED							
		√ NCTO	TIME DELAY RELAY CONTACT. ON DELAY, NORMALLY CLOSED, TIME OPEN							
Sov		o/vo	SOLENOID OPERATED VALVE							
			MOTOR CONTROL CENTER DRAWOUT STABS							
\boxtimes	2 -		MOTOR STARTER WITH THERMAL OVERLOADS. NUMBER INDICATES NEMA SIZE							
		0L 	MOTOR OVERLOAD CONTACT							
2)	2	2	MOTOR, NUMBER INDICATES HORSEPOWER							
			INDICATING LIGHT, PUSH-TO-TEST. LETTER INDICATES COLOR. R=RED B=BLUE G=GREEN A=AMBER W=WHITE							
		M	CONTACTOR OR RELAY COIL.LETTER OR NUMBER IS DESIGNATION							
		M ++-	NORMALLY CLOSED CONTACT.LETTER OR NUMBER IS DESIGNATION							
			NORMALLY OPEN CONTACT. LETTER OR NUMBER IS DESIGNATION							
		ЕТМ	RUNNING TIME METER, NON-RESETTABLE							
	20A	5A	FUSE, NUMBER INDICATES RATING							
			CONTROL TRANSFORMER, RATING AS NOTED ON DRAWINGS OR AS REQUIRED BASED ON LOAD SERVED.							
	KW		KILOWATT METER							
PS		J.	PRESSURE SWITCH. CONTACT ACTION AS NOTED ON DRAWINGS							

CON PL	DUIT. AN	SINGLE LINE DIAGRAM	SCHEMATIC DIAGRAM	DESCRIPTION
	-	<u></u>		POWER TRANSFORMER. RATINGS AS NOTED ON DRAWINGS
F)			DUPLEX RECEPTACLE. 20A, SPEC GRADE GROUNDING TYPE, UNLESS OTHERWISE NOTED ON DRAWINGS.
•	•			TELEPHONE OUTLET
)			JUNCTION BOX OR CONDUIT FITTING AS NOTED OR REQUIRED.
	LS		7	LEVEL SWITCH, CONTACT ACTION AS NOTED ON DRAWINGS
				CONTROL PANEL OR EQUIPMENT AS NOTED
]FS		7	FLOW SWITCH, CONTACT ACTION AS NOTED ON DRAWINGS
	5			FLUSH TOGGLE SWITCH, SINGLE POLE, SINGLE THROW
	5 3			FLUSH TOGGLE SWITCH, THREE WAY
				FLUORESCENT FIXTURE.SEE LIGHTING SCHEDULE.
Н	\supset			LIGHTING FIXTURE, WALL MOUNTED SEE LIGHTING SCHEDULE
P	В			MH-MANHOLE PB-PULLBOX HH-HANDHOLE OR AS NOTED ON DRAWINGS
_	·			TELEPHONE CONDUIT. SIZE AS NOTED
	;			GROUNDING GRID OR GROUNDING CONDUCTOR SIZE AS REQUIRED OR AS NOTED ON DRAWINGS
-G-	—			GROUND PIGTAIL. SIZE AS NOTED ON DRAWINGS
_	—g —			EXOTHERMIC GROUND CONNECTION
-G -	1			BOLTED GROUND CONNECTION
	- 0			CONDUIT BENDING UP
	- •			CONDUIT BENDING DOWN
				UNDERGROUND OR CONCEALED CONDUIT
				EXPOSED CONDUIT.
-/// PBII	,3,5			HOMERUN CONDUIT WITH 3 CONDUCTORS, NEUTRAL(S) AND GROUND, PANEL 'PB'-CIRCUITS 1,3,5. MINIMUM CONDUIT SIZE SHALL BE 3/4' UON. NO HASH MARKS INDICATES 3/4'C (2)*12 +(1)*12G
	•)			DRIVEN GROUND ROD/TEST WELL 3/4" X 10' Cu CLAD STEEL
				PANELBOARD OR AS NOTED ON DRAWING
_ \	~			LIQUIDTIGHT FLEXIBLE CONDUIT
(X)	(X)	XXX		CONDUIT NUMBER 'XXX', REFER TO CONDUIT SCHEDULE FOR DESCRIPTION

CONDUIT PLAN	SINGLE LINE DIAGRAM	SCHEMATIC DIAGRAM	<u>DESCRIPTION</u>
\$ ^M			MANUAL MOTOR STARTER
- 111	-	-	GROUND
	،۲۰۲۰ _°	،۲۰۲۰	HEATER, RATING AS NOTED ON DRAWING
			HORN OR AUDIBLE SIGNAL
Ø	Ø	Ø	PHASE
			TERMINAL
DS			MAGNETIC DOOR SWITCH
T			CONDUIT STUB OUT
□¦xx	/ xx 		FUSED DISCONNECT SWITCH, XX = AMP RATING

GENERAL NOTES:

- I. EXPOSED RACEWAYS SHALL BE RIGID GALVANIZED STEEL.
- 2. UNDERGROUND RACEWAYS SHALL BE ROUTED 24 BELOW GRADE. RACEWAYS SHALL BE PVC SCHEDULE 40 AND ENCASED IN SLURRY AT ROADWAYS.



DRAWING NO.	POINT LOMA WASTE WATER TREATMENT PLANT										
E-OI	BIOLOGICAL AERATED FILTER PILOT STUDY										
SHEET NO.	ELECTRICAL										
19	SYMBOLS AND ABBREVIATIONS										
	WATED										
	CITY OF SAN DIEGO, CALIFORNIA NA. SEWER NA										



WARNING 1/2

THIS BAR DOES NOT MEASURE I'
THEN DRAWING IS
NOT TO SCALE.

BROWN AND CALDWELL

SCALE

HORIZONTAL NONE

NONE

VERTICAL

METROPOLITAN WASTEWATER DEPARTMENT

City of San Diego



										SHEET	19 01	- 22 SHE	EIS		W.O. NA
			DRAWING ST	ATUS						PROJECT MANAGER			DATE		
١0.	DATE	REQ.	REVISION DESCRIPTION	DRAWN	CKD	APD	PE	ЕМ	QA/QC	DESCRIPTION	BY	APPROVED	DATE	FILMED	
															DESIGN ENGINEER
															CONTROL CERTIFICATION
															188-1692
															LAMBERT COORDINATES
										CONTRACTOR		00000- 19 <i>-</i> D			

MC MCC MCM

MAINTAINED CONTACT MOTOR CONTROL CENTER THOUSAND CIRCULAR MILS MOTOR CIRCUIT PROTECTOR MANHOLE